

Government of Tripura  
Directorate General of Fire Service  
Tripura, Agartala.

Phone: 0381-2326451. Fax: 0381-2324826. Email: [dfireservicetripura@gmail.com](mailto:dfireservicetripura@gmail.com). Website: [www.fireservice.tripura.gov.in](http://www.fireservice.tripura.gov.in)

No. 460-61 /3-8/TFS/2019

Dated, Agartala, the 14<sup>th</sup>, Januray, 2019.

To  
The Principal,  
St. Xavir's H.s. School,  
Don Bosco, Pathaliaghat,  
Bishramganj, sepahijala Tripura,  
Pin - 799 103.

Subject :- Installation of the fire safety measures in the St. Xavir's H.s. School, Don Bosco, Pathaliaghat, Bishramganj, sepahijala Tripura.

Sir,

Please refer to your letter No.STX/FIR/1-12/18 dated 1<sup>st</sup> December, 2018.

It is to inform you that a team of officers from Fire Service Department have visited your Institute on 13.12.2018 and found that fire safety measures have been installed adequately. Besides, as per suggestion of our inspection team it is advised to install Hose reel 30 mtrs. one no. each in Girls Hostel as well as Boys Hostel building to avoid any fire incident. You are requested to engage trained manpower to handle the fire extinguisher in case of emergency. Accordingly, **fire fighting arrangement / NOC in favour of your St. Xavir's H.s. School** is hereby issued subject to above condition.

The existing fire fighting arrangements should be periodically checked by your own trained staff and if any defect is found that corrective measures should be taken immediately. The authority of St. Xavir's H.s. School should communicate this Office after 1(one) year for condition next fire audit to ensure that the Fire fighting equipments / arrangements are in good condition.

Yours faithfully,

*Uttam Kr. Bhaumik*  
14.1.19

(Uttam Kr. Bhaumik, IPS)  
Joint Director,

For Director General Fire Service,  
Tripura, Agartala.  
UTTAM KR. BHANUMIK, (IPS)  
Joint Director Fire Service,  
Tripura, Agartala

Copy to :-

The Divisional Fire Officer, West Tripura, Agartala for favour of Information. This has a reference to his letter vide No.10503/3-8/FIRE(W)/2018 dated 19.12.2018.